

1. ALL LIGHTING FIXTURES EMERGENCY BATTERY BALLASTS TO BE SERVED BY UNSWITCHED SIDE OF CIRCUIT IN ADDITION TO BEING SWITCHED WITH OTHER ROOM LIGHTING.

◆ INDUSTRIAL TYPE LUMINAIRES IN UNFINISHED AREAS, WHICH ARE NEAR OBSTRUCTIONS SUCH AS DUCTS, AHUS, AND PIPES, SHALL BE:

- A) SUSPENDED SO THAT BOTTOM OF LUMINAIRE IS NO HIGHER THAN BOTTOM OF OBSTRUCTION.
- B) LOCATED AT HEIGHT OF LOWEST LUMINAIRE.
- C) MINIMUM HEIGHT: 8'-0".
- D) SHALL NOT BE LOCATED UNTIL LOCATIONS OF OBSTRUCTIONS ARE DETERMINED.
- E) PLACED FOR BEST ILLUMINATION OF SPACE.

◆ THREE WAY SWITCH CONTROLS ALL LIGHTS IN PENTHOUSE WITH SWITCH ON SHEET EL2.2.B ON COLUMN LINE 14B.

SMITHGROUP, INC
35 EAST WACKER
SUITE 2200
CHICAGO, IL 60601
T 312.641.0770
F 312.641.6728
www.smithgroup.com


JJR, LLC
35 EAST WACKER DRIVE
SUITE 2200
CHICAGO, ILLINOIS 60601
312.641.0510 T
312.641.0668 F
www.jjr-us.com

Affiliated Engineers, Inc.
5902 Research Park Boulevard
Madison, Wisconsin 53719
Tel 608.238.2616 Fax 608.238.2614

Thornton Tomasetti, Inc.
330 N. Wabash Avenue, Suite 1500
Chicago IL 60611-7622



TERRA
ENGINEERING LTD.
225 West Ohio Street, 4th Floor
Chicago, Illinois 60654
T:(312)467-0123 F:(312) 467-0220

[illegible]

	ISSUED FOR CONSTRUCTION			07/03/12
REV. NO.	DESCRIPTION	BY	APP'D	DATE

Argonne
NATIONAL LABORATORY

FMS
Facilities Management Services

PROJECT TITLE	ADVANCED PROTEIN CRYSTALLIZATION FACILITY, ARGONNE NATIONAL LABORATORY
---------------	--

PROJECT NO	08541-00
DRAWING TITLE	

02 PENTHOUSE
ELECTRICAL LIGHTING
PLAN A

DESIGNED DLW	A/E CADD FILE EL2.2.A	FACILITY NO(S)
DRAWN DLW	A/E DWG. NO. EL2.2.A	
CHECKED BRB	CAD NO:	
PROJECT MANAGER	DWG STATE	
ANL - JESSE ADAMS DATE - 04/26/11	BIND ORDER	
CITY DOCUMENT NUMBER		REV. NO.
J446-101-W- EL2.2.A		

Plot Date:

1 02 PENTHOUSE ELECTRICAL LIGHTING PLAN A
1/8" = 1'-0"